



Test Report

District Level Water Analysis Laboratory, U.P. Jal Nigam, (Rural)
Sant Kabir Nagar

Address- Office of Executive Engineer, Construction division, U.P Jal Nigam, Near Over Bridge Industrial Area, Khalilabad, Sant
Kabeer Nagar, 272175 Certificate No. 10.0960

Report No:	SKN/April/05	Issue Date:	24/04/2024	Page No	1-2
Remark		Address:	UPJN Sant Kabir Nagar	Mob:	9918803036

Customer Details


Name and contact info. of customer	G.R. Academy, 9118112345
Office Name and Address	G.R. Academy Devdand Post Madhavpur, Khalilabad Sant Kabir Nagar
Ref Letter No & Date	23/04/2024

Basic details of sample

District	Sant Kabir Nagar	Block	Khalilabad
Gram Panchayat	-	Village	-
Habitation	-	Location	Devdand, Khalilabad
Water Source	HP,	Sample No.	SKN/05
Quantity of Sample	1 liter	Date of Collection	23/04/2024
Receiving Date	23/04/2024	S. Collector	Devendra Yadav
Sample Depositor	Devendra Yadav	Sampling Method	
Analysis Start Date	23/04/2024	Analysis Completion Date:	24/04/2024

Technical Data of Analysis

1	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	pH @ 25°C	7.32	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2017 (Electrometric method)
2	Turbidity NTU	2.50	1	5	IS 3025 (Pt 10):2017
3	TDS mg/L	310	500	2000	IS 3025 (Pt 16):2017
4	Fluoride mg/L	0.20	1	1.5	APHA 23 rd Edition 4500-F Method C (Electrode method) 2017


PRINCIPAL
G. R. ACADEMY
Devdand, Khalilabad
Sant Kabir Nagar


MANAGER
G. R. ACADEMY
Devdand, Khalilabad
Sant Kabir Nagar

5	Total Hardness mg/L	280	200	600	IS 3025 (Part 21) 2019
6	Total Alkalinity mg/l	235	200	600	IS 3025 (Part 23) 2019
7	Chloride mg/L	56.2	250	1000	IS 3025 (Part 32) 2019
8	Iron mg/L	0.14	1	1	APHA 23 rd Edition 3500-Fe Method B (Phenanthroline Method) 2017
9	Sulphate mg/L	26.9	200	400	APHA 23 rd Edition 4500-SO ₄ Method E (Turbidity Method) 2017
10	Nitrate mg/L	Below Detection Limit	45	45	APHA 23 rd Edition 4500-NO ₃ -Method D (UV Screening Method) 2017
11	Calcium mg/L	72.6	75	200	IS 3025 (Part 40) 2019
12	Magnesium mg/L	23.72	30	100	IS 3025 (Part 46) 2019
13	Color (CU) at pH	5	5	15	APHA 23 rd Edition Color 2120 B (Visual Comparison Method)
14	Arsenic (As)	Below Detection Limit	0.01	0.05	APHA 23 rd Edition (AAs)

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 10 days (in case of non-perishable items only) from the date of issue of tests reports.

Prepared By-

(Arpan)
 Technical Manager
 Sant Kabir Nagar Laboratory
 District - Meerut
 Sant Kabir Nagar U.P.

Authorized Signatory:

(Arpan)


Testing Lab In charge

Laboratory Contact details

Email- arpanmishad224168@gmail.com

Mob-9918803036

x.....End of Report.....x


PRINCIPAL
 G. R. ACADEMY
 Devdand, Khalilabad
 Sant Kabir Nagar


MANAGER
 G. R. ACADEMY
 Devdand, Khalilabad
 Sant Kabir Nagar